

HTMRTR2R

EXTRACT SERIES MULTIROOM KIT
THROUGH ROOF FOR 2 ROOMS



hometechTM
The Ventilation Specialists



SPECIFICATIONS

Air Flow:	42-52l/s (per room)
Diameter:	150dia
Duct Run:	Up to 3m per room, no more than 6m separation
Noise:	45dB @ 0.5m
Install Location:	Wet rooms
Minimum Clearance:	450mm, options for skillion ceilings
Rooms Served:	Two
Ventilation Type:	Intermittent Extract
Filter:	Optional (Laundry)
Control:	Wall Switch, Single Speed
Power:	35W
Add-ons	<ul style="list-style-type: none">• Timer• Humidity sensor

PRODUCT DESCRIPTION

Two room roof mounted venting system with proprietary flashing, vent cap and in-line fans to provide mechanical extraction ventilation. The motor services two rooms up to 6m apart.

KEY BENEFITS

- Efficient operation: Roof penetrations often offer the path of least resistance for ducting, which in turn leads to more efficient performance from fans.
- Two-in-one: One penetration serving multiple spaces minimises exterior penetrations and reduces risk.
- Peace of mind: backed up by a 10-year leak proof guarantee.

APPLICATIONS

*This system is suitable for, but not limited to the following areas:

- Single level / top floor installations
- 2 rooms
- Bathrooms, toilets, internal laundries

PRODUCT COMPLIANCE

- G4: Extract air volume exceeds 25l/s for bathrooms and/or 40l/s for laundries.
- Healthy Homes: Bathroom Ventilation
- B2, E2
- BRANZ appraisal 665

ELECTRICAL

- Electrical connection excluded.
- All fans to be connected to an isolating switch as per AS/NZS 3000:2018.

WARRANTY

- 10 Year LEAK PROOF GUARANTEE
- 10 Years for materials and workmanship
- 1 Years for fan motor

Terms and conditions apply.

EXPANSIONS / ALTERNATIVES

- HTMRTR2RFC : For fire rated ceiling applications
- HTBKTRIL : Alternative using inline fan
- HTBKTRSK : Alternative for use in no cavity/skillion ceiling applications

LIMITATIONS

- Minimum of 350mm between ceiling and roof line is required.
- Sufficient replacement air is required for extract efficiency. Replacement air can be achieved through opening a window or undercut to a door of 10mm minimum.

INSTALLATION

To be carried out by Hometech to manufacturer's recommendations:

- Roof mounted system installed with proprietary Hometech roof flashing (BRANZ Appraisal 665) and vent cap.
- Ceiling diffuser to be located as close to outside edge of shower enclosure. For shower over bath diffuser to be as close to centre of bath.
- Fire protection available that is compliant is AS/NZS 15304.4:2014.

MAINTENANCE

- At regular intervals following installation, the fan should be inspected and cleaned to ensure there is no build-up of dirt or other deposits. It is recommended this is done as part of a scheduled yearly maintenance program.
- The face can be cleaned without removal by wiping the inlets and front face with a damp cloth.
- If any problems arise, please contact your installation professional.

CAD DRAWING

Full CAD drawing(s) available upon request

